



**THE
NATIONAL
BOARD**

OF BOILER AND
PRESSURE VESSEL
INSPECTORS

August 26, 2010

Dr. Jens Mohring
Bopp & Reuther Sicherheits
Carl Reuther Strasse 1
D-68305 Mannheim,
GERMANY

**SUBJECT: Capacity Certification, Valve Type: Si 91/95, SiZ, 2507 RL
(NB Cap Cert No.: BOP-M72076)**

Dear Mr. Mohring:

Enclosed please find a copy of the test report numbers 28516S and 28518S performed at the **National Board Testing Laboratory** on May 18, 2010 which demonstrate successful completion of testing for capacity certification of the subject valve as required by paragraphs PG-73.3.3 and UG-136(c)(3) of Sections I and VIII of the ASME Code. Successful completion of this testing will also permit recertification for Section III (Class 2 and 3) applications.

Bopp & Reuther Sicherheits is hereby granted capacity certification and authorization to apply the "NB" mark to the valve type listed in the scope of certification. This authorization is valid for the above location and only while the organization holds a current ASME "V", "NV" or "UV" Certificate of Authorization and is fully implementing its quality system as accepted by the National Board.

SCOPE OF CERTIFICATION

Valve Type: Si 91/95, SiZ, 2507 RL

Organization Type: Manufacturer

**Certified Rating Value, Sizes & Pressure Ranges:
As Listed in NB-18**

Certification Expiration Date: August 9, 2015

1055 CRUPPER AVE.
COLUMBUS, OHIO
43229-1183
U.S.A.
614.888.8320

EXECUTIVE
Fax 614.888.0750
TECHNICAL
Fax 614.847.1828
PRESSURE RELIEF DEPT.
Fax 614.848.3474
ORDER DEPARTMENT
Fax 614.847.1147
TRAINING DEPARTMENT
Fax 614.847.5542

EMAIL
information@nationalboard.org

WEB SITE
nationalboard.org

Yours Truly,

Joseph F. Ball, P. E.
Director, Pressure Relief Department

*File: MF: 100826BOPM72076.DOC
REVISION 1: Code Sections Revised*